



**TITLE: Refrigerator or combined refrigerator and water-pack freezer:
intermittent mains-powered, compression cycle**

Product verification protocol: E003/RF03-VP.5

Applies to specification ref(s): E003/RF03.7

Issue date: 02 December 2024

Date of previous revision: 22 October 2020

Contents

1. Scope	2
2. Normative references.....	2
3. Terms and definitions.....	3
4. Applicability.....	5
5. Type-testing procedure.....	6
5.1 Evidence of conformity assessment.....	6
5.2 Number of samples	6
5.3 Test procedure	6
5.3.1 Test 1: Type examination.....	6
5.3.2 Test temperatures and intermittent power profile	8
5.3.3 Test 2: Cool-down, initial stabilization, and power consumption.....	9
5.3.4 Test 3: Humidity control.....	10
5.3.5 Test 4: Stable running and continuous power consumption	10
5.3.6 Test 5: Stable running and intermittent power consumption	11
5.3.7 Test 6: Water-pack freezing capacity, storage compartment capacity and power consumption.....	11
5.3.8 Test 7: Day/night, frozen water-pack storage and power consumption	13
5.3.9 Test 8: Compressor starting	14
5.3.10 Test 9: Holdover time.....	15
5.3.11 Test 10: Freeze protection classification	15
5.3.12 Test 11: Door opening.....	16
5.3.13 Test 12: Minimum rated ambient temperature	16
5.4 Test criteria for qualification.....	17
6. Quality control checklist.....	18
6.1 Quality control standards	18
6.2 Quality control checklist	18
6.3 Quality control evaluation.....	18
7. Prequalification evaluation	19
8. Modified appliances.....	19
Annex 1 – General test conditions	20
Annex 3 – Temperature sensor specification.....	27
Annex 4 – Methodology for measurement of ice production.....	27
Annex 5 – Methodology for freeze protection analysis and grading	28
Revision history	29

1. Scope

This document describes the procedure for verifying the performance of compression cycle refrigerators or combined refrigerator and water-pack freezers. Previously, an appliance that passed the relevant tests would be prequalified with a specific temperature zone designation. Three temperature zones are described: [moderate zone](#), [temperate zone](#) and [hot zone](#); the scope of each category is defined in Section 3. However, from the point of issuance of this verification protocol, all appliances must pass the relevant tests in the [hot zone](#). In addition, appliances must demonstrate a minimum [rated ambient temperature](#) of +10°C. This is in accordance with the revised performance specification as described in **PQS E003/RF01.4**.

Additionally, from the point of issuance of this protocol, the manufacturer is required to specify the minimum average daily duration of power (e.g., 8 to 20 hours of reliable electricity per typical day; less than 8 hours of reliable electricity per typical day) required for the appliance to operate. Relevant tests in this protocol will then provide the appliance with this indicated amount of power.

2. Normative references

EMAS: European Union Eco-Management and Audit Scheme.
EN ISO 6270-1 / ASTM D2247 / EN 13523-26: Determination of resistance to humidity – Part 1: Continuous condensation.
EN ISO 6270-2 / EN 13523-25: Determination of resistance to humidity - Part 2: Procedure for exposing test specimens in condensation-water atmospheres.
GHS Rev 5. United Nations: Globally Harmonized System of Classification and Labelling of Chemicals.
IEC 60335-1: Amendment 1: Household and similar electrical appliances - Safety - Part 1: General requirements.
IEC 60335-2-24: 2007: Household and similar electrical appliances - Safety - Part 2-24: Particular requirements for refrigerating appliances, ice-cream appliances and ice-makers.
IEC 60364-1: 2005: Low-voltage electrical installations - Part 1: Fundamental principles, assessment of general characteristics, definitions.
IEC 61000-6-1 edition 2.0: 2005: Electromagnetic compatibility (EMC) Generic standards - Immunity for residential, commercial and light-industrial environments.
IEC 61000-6-3 edition 2.1: 2011: Electromagnetic compatibility (EMC) Generic standards - Emission standard for residential, commercial and light-industrial environments.
IEC 62552: 2007: Household refrigerating appliances – Characteristics/tests.
ISO 2409: 2013: Paints and varnishes – cross cut test (external cabinet).
ISO 6272 / EN 13523-5: Impact resistance - external cabinet.
ISO 9001: Quality Management Systems – Requirements.
ISO 14001: 2004: Environmental management systems - Requirements with guidance for use.
ISO 20282-1: 2006: Ease of operation of everyday products - Part 1: Context of use and user characteristics.
ISO/IEC 17025: 2005: General requirements for the competence of testing and calibration laboratories.

WHO/PQS/E005/IP01: Water-packs for use as ice-packs, cool-packs and warm-packs.

WHO/PQS/E006/TH02.2: Fixed gas or vapour pressure dial thermometer.

WHO/PQS/E006/TH06.2: Integrated electronic maximum-minimum thermometer, with factory programmed alarms, for vaccine refrigerators and freezers.

3. Terms and definitions

Acceptable compartment humidity: The acceptable compartment humidity is 55% or lower at +2-8°C during relevant verification testing. However, transient excursions during testing above this value will be tolerated, with the following limits:

- No excursion may exceed 65% at +2-8°C when the appliance is supplied with power and after any initial starting period defined in verification protocols.
- The average compartment humidity during relevant verification testing remains 55% or lower at +2-8°C when the appliance is supplied with power and after any initial starting period defined in verification protocols.

Acceptable temperature range: The acceptable temperature range for storing vaccine is +2°C to +8°C. However, transient excursions outside this range will be tolerated, within the following limits:

- No excursion must exceed +20°C ($\pm 0.5^\circ\text{C}$) for any amount of time.
- No excursion must drop below -0.5°C for any amount of time.
- No excursion must drop below 0°C for longer than 1 hour.
- Following an excursion below 0°C, the appliance must return to safe operating temperature (i.e., consistently between +2°C and +8°C) within 2 hours. This duration will be measured from the moment the temperature drops below 0°C and up until it returns to +2°C.

The cumulative effect of any excursions within the above range will be assessed over the five-day period of the *day/night* test. For this test, the calculated mean kinetic temperature (MKT)¹ must remain within the range +2°C to +8°C when the default activation energy is set at 83,144 kJ per mol. Using the recorded temperature data, an MKT figure will be calculated for each sensor. The worst-case result will determine the outcome of the test. Excursions in other tests will be noted and must not exceed the defined upper and lower limits.

Ambient humidity: The relative humidity (%) of the chamber in which the appliance is being tested.

Compartment humidity: The relative humidity (%) of the vaccine compartment of the appliance.

Freezing temperature on walls / lining of vaccine compartment:

For sensors placed in direct contact with the walls /lining of the vaccine compartment, freezing temperature is defined as any of the following conditions:

- Excursion between -0.5°C and 0°C for longer than 1 hour.
- Excursion equal to or below -0.5°C for any amount of time.

¹ Refer to Seevers, R. et al. The Use of Mean Kinetic Temperature (MKT) in the Handling, Storage and Distribution of Temperature Sensitive Pharmaceuticals. Pharmaceutical Outsourcing, May/June 2009.

- Inability to return to safe operating temperature (i.e., consistently between +2°C and +8°C) within 2 hours following an excursion equal to or below 0°C.

Freeze protection classification:

- **Grade A, user-independent freeze protection (UIFP):** When the appliance is used within its nominated temperature range (temperature zone +43°C, +32°C or +27°C and minimum rated ambient temperature) there is no intervention required by the user to ensure that the vaccines will not be exposed to temperatures below 0°C whatever the position of the vaccine in the vaccine compartment.
- **Grade B, user-dependent freeze protection (UDFP):** Even if the appliance is used within its nominated temperature range, the user must comply with a procedure provided by the manufacturer and requiring one level of intervention (e.g., the requirement to use baskets or other items) in order to avoid vaccine freezing.
- **Grade C, user-dependent freeze protection (UDFP):** Even if the appliance is used within its nominated temperature range, the user must comply with a procedure provided by the manufacturer requiring more than one level of intervention in order to avoid vaccine freezing. (e.g., the requirement to use baskets and insulation barriers or covers).

Gross volume: The measured volume of the airspace inside the internal compartment of the appliance with the door or lid shut. For combined appliances the gross freezer volume and the gross refrigerator volume are reported separately.

Holdover time: The time in hours during which all points in the vaccine compartment remain between +2°C and +8°C, at the maximum ambient temperature of the temperature zone for which the appliance is rated, after the power supply has been disconnected.

Hot zone: Hot zone appliances must operate at a steady +43°C ambient temperature and over a +43°C/+25°C day/night cycling temperature range.

Humidity control: A functional capability of a vaccine storage compartment, by which relative humidity levels are controlled while power is available such that limited or no condensation accumulates on compartment, vial or secondary carton surfaces and mould growth is inhibited.

In writing: means communication by letter, fax or email.

Legal manufacturer: The natural or legal person with responsibility for the design, manufacture, packaging and labelling of a product or device before it is placed on the market under his own name, regardless of whether these operations are carried out by that person himself or on his behalf by a third party.

Minimum rated ambient temperature: The lowest constant ambient temperature at which the acceptable temperature range can be maintained with a full vaccine load. All models must be able to operate at a continuous minimum ambient temperature of +10.0°C or lower whilst maintaining the acceptable temperature range.

Moderate zone: Moderate zone appliances must operate at a steady +27°C ambient temperature and over a +27°C/+10°C day/night cycling temperature range.

Montreal Protocol: Montreal Protocol on Substances that Deplete the Ozone Layer.

[Phase change material \(PCM\)](#): A material, other than water, which changes state between solid and liquid or changes between two different solid crystallization states over a defined temperature range, absorbing or releasing heat during the phase change. This process is reversible and can be useful for thermal control in cold chain devices and products.

[Primary container](#): Vial, ampoule, prefilled device, plastic dispenser or tube containing vaccine or diluent. Some products are supplied in a light card carton containing a single vial, ampoule, vial pair, vial-ampoule pair, or prefilled device.

[Reseller](#): A commercial entity, licensed to act on behalf of a legal manufacturer, and which carries product liability and warranty responsibilities no less onerous than those carried by the legal manufacturer.

[Temperate zone](#): Temperate zone appliances must operate at a steady +32°C ambient temperature and over a +32°C/+15°C day/night cycling temperature range.

[User-Dependent Freeze Protection \(UDFP\)](#): Refrigeration technology that requires appliance users (e.g., healthcare workers) to perform specific actions (user-interventions) in order to ensure vaccine protection against freezing temperatures (e.g., store vaccines in baskets, away from compartment wall surfaces).

[User-Independent Freeze Protection \(UIFP\)](#): Refrigeration technology that requires appliance users (e.g., healthcare workers) to perform no specific actions (user-interventions) in order to ensure vaccine protection against freezing temperatures.

[User-intervention](#): Any activity that is required to be executed by appliance users in order to ensure vaccine protection against freezing. Activities could include, but are not limited to, basket storage, storage compartment covers, thermostat/fuel adjustment, and combustion component replacement.

[Vaccine net storage capacity](#): The net storage capacity is the space where it is suitable (both thermally and ergonomically) to store vaccines. Where manufacturers are declaring more than one vaccine storage capacity for the same gross volume and external dimensions, manufacturers must prequalify with different branding, one model for each different storage volume.

[Water-pack](#): A flat, leak proof, plastic container, filled with tap water, complying generally with specification **PQS/E005/IP01**.

[Water-pack freezing capacity](#): The maximum weight of water-packs which can be fully frozen, in one batch, during a 24-hour freezing cycle. During this period the temperature of the vaccine storage compartment must remain within the acceptable temperature range. The temperature of the water-pack freezing compartment must remain below -3°C, except during the actual freezing process after unfrozen water-packs have been loaded.

[Ice-pack storage capacity](#): The maximum number of fully frozen water-packs that can remain fully frozen at the end of water-pack storage compartment testing.

4. Applicability

Type-testing will be carried out by an independent **ISO/IEC 17025** testing laboratory, accredited by WHO.

5. Type-testing procedure

5.1 Evidence of conformity assessment

Appliances must carry the CE mark, UL mark and/or equivalent internationally accepted evidence of conformity assessment.

5.2 Number of samples

The [legal manufacturer](#) or [reseller](#) must supply the testing laboratory with a full duplicate set of the Product Dossier already supplied to WHO in accordance with the requirements of specification clause 7. One sample of the appliance is required. Ensure that the voltage and frequency rating of the sample(s) is suitable for the country where the test laboratory is located².

5.3 Test procedure

5.3.1 *Test 1: Type examination*

- **Step 1:** Unpack the appliance. Using the manufacturer's installation instructions only, set up the system components. Record the process and any problems encountered.
- **Step 2:** Check all samples for similarities between different models³, dissimilarities between samples of one model, any defects or damage or any problem that make it difficult or impossible to test the appliance.
- **Step 3:** Record any differences between the samples ordered and those received.
- **Step 4:** Tabulate the following information for each model submitted for examination. Obtain any additional supporting information required [in writing](#) from the [legal manufacturer](#) or [reseller](#) and attach this information to the report:

Identification

- Code (a unique identifier to be assigned by the testing laboratory);
- Model;
- [Legal manufacturer](#) or [reseller](#);
- Appliance type (i.e. vaccine refrigerator or combined appliance);
- Country of origin;
- Conformity assessment markings (e.g. CE mark);
- Temperature zone rating against which the appliance is to be tested.

Performance characteristics (Note: laboratory is to report by clause and in this same order as below)

² If there is any doubt that the performance of the appliance will vary under the other nominal voltage/frequency combinations supplied by the manufacturer, he must be asked to comment [in writing](#).

³ The purpose of this inspection is to establish whether appliances offered by competing companies are re-badged versions of an otherwise identical appliance.

- Temperature zone rating sticker conforms/does not conform to Annex 1 design (specification clause 4.2.1).
- Refrigeration type and input voltage conforms/does not conform to specification clause 4.2.2.
- Design of vaccine storage compartment conforms/does not conform to specification clause 4.2.3.
- Vaccine [freeze protection classification](#) sticker conforms/does not conform to Annex 3 specification clause 4.2.4 (note Grade A, B or C).
- Combined appliances only: Water-pack storage compartment capacity conforms/does not conform to specification clause 4.2.6.
- Thermostat type conforms/does not conform to specification clause 4.2.8.
- The data logger conforms/does not conform to the requirements of E006/DL01. The appliance has a display that meets the requirements of one of the five configurations identified in Table 1 of clause 4.2.9.
- Indicator light conforms/does not conform to specification clause 4.2.10.
- Power system requirements and voltage conforms/does not conform to specification clause 4.2.13.
- Condensation management and defrost conforms/does not conform to specification clause 4.2.14.
- Lock conforms/does not conform to specification clause 4.2.15.
- Corrosion resistance conforms/does not conform to specification clause 4.2.16.
- Electrical safety rating conforms/does not conform to specification clause 4.2.17.
- Markings conform/do not conform to specification clause 4.2.18.
- Vaccine storage advice conforms/does not conform to specification clause 4.2.19.
- Electromagnetic compatibility conforms/does not conform to specification clause 4.2.20.

Environmental requirements:

- Ambient temperature range during transport and storage conforms/does not conform to specification clause 4.3.1.
- Ambient humidity range during transport, storage and use conforms/does not conform to specification clause 4.3.2.

Physical characteristics:

- Overall dimensions conform/do not conform to specification clause 4.4.1.
- Weight conforms/does not conform to specification clause 4.4.2.

Interface requirements:

- Electrical components conform/do not conform to specification clause 4.5.1.
- Power lead conforms/does not conform to specification clause 4.5.2.

Human factors:

- General design of the product conforms/does not conform to specification clause 4.6.1. Manufacturer to certify in writing that the conformance to clause 4.6.1.
- Control panel, indicator light, and thermometer conform/do not conform to specification clause 4.6.2.
- PQS stickers conform/do not conform to specifications clause 4.6.3.

Materials and construction:

- Record materials of all major visible components.
- Refrigerant conforms/does not conform to clause 4.7.1.
- Thermal insulation foaming agent conforms/does not conform to specification clause 4.7.2.
- Other restricted materials listed in clause 4.7.3 are/are not present.

PCM:

- PCM, if used, conforms/does not conform to the specification in clause 4.7.4. Manufacturer to provide documentation confirming compliance with **WHO/PQS/E005/PCMC0.1**– PCM specification for Phase-change material containers.

Physical data:

- Record major rectangular dimensions in centimetres (± 1.0 cm).
- Record weight in kilograms (± 0.25 kg).
- Record internal volume of refrigerator and freezer compartment in litres.
- Record gross volume of all vaccine and water-pack storage compartments
- Record estimated vaccine net storage capacity in litres.
- Record maximum water-pack capacity in kilograms (if freezer included).

Warranty

- Warranty conforms/does not conform to specification clause 4.8.

Essential spare parts

- Spare fuses (if used) conforms/does not conform to specification clause 4.9.1.
- List of spare parts conforms/does not conform to specification clause 4.9.1.

Disposal and recycling

- Hazardous materials information conforms/does not conform to specification clause 4.10.

Instructions:

- Instructions conform/do not conform to specification clause 4.11.

Packaging

- Packaging conforms/does not conform to specification clause 5.
- **Step 5:** Take a three-quarter view digital photograph of the appliance with the door open. Take additional photographs showing all external surfaces of the appliance, the interior layout, the [vaccine storage compartment](#), the compressor or cooling system and a close-up of the thermometer, indicator light(s), the control(s), control panel and any special features or identified weaknesses of the appliance. High resolution digital images should be provided for attachment to the PQS report.

Acceptance criteria: Inspection indicates full conformity with all major specification requirements. System setup must be straightforward and trouble-free.

5.3.2 Test temperatures and intermittent power profile

All appliances are to be tested to [hot zone](#) temperatures and per Annexes 1, 2 and 3. Record test room ambient and internal cabinet temperatures for at least

48 hours prior to all tests. Additionally, certain tests involve intermittent power. This should match the maximum power requirement specified by the manufacturer. If the manufacturer specified 8 hours per day of power required for the device to operate, during tests with intermittent power, the appliance must be provided with 8 hours of continuous power followed by 16 hours no power. Similarly, if the manufacturer specifies 4 hours per day of power required, during tests with intermittent power, the appliance must be provided with 4 hours of continuous power followed by 20 hours of no power.

5.3.3 Test 2: Cool-down, initial stabilization, and power consumption

- **Power:** Intermittent.
- **Step 1:** Set the test chamber temperature to +43°C and leave for 48 hours with the appliance empty, the lid or door open, and the power supply switched off.
- **Step 2:** Close the lid or door of the appliance, commence with intermittent power of 20 hours of continuous power followed by 4 hours with no power per 24-hour day and leave it to initially stabilize. Initial stabilization is accomplished when the appliance demonstrates all of the following:
 - The thermal storage has been cooled for a time period no less than the cool down time period stated in the instructions provided by the manufacturer. (e.g., if instructions state cool down time is 3 days then at least a 3-day cool down test is required);
 - The internal temperatures in the [vaccine storage compartment](#) are within the [acceptable temperature range](#); and
 - The cooling system has exhibited consistent on/off operation for the final two days of this test (e.g. the same number of on/off cycles per day for the final two days).
- **Step 3:** During stabilization, record temperatures every minute, and continue to do so for 24 hours after stabilization. During this period measure the energy consumption and determine the compressor duty cycle. Measure the duty cycle by timing from the end of one cycle to the end of a corresponding cycle approximately 24 hours later. Calculate the percentage 'on' time over this period. Measure electricity consumption over the same time scale and report as kWh/day.

Acceptance criterion: Stabilized internal temperatures between +2°C and +8°C in the vaccine storage compartment and below -3°C in the water-pack freezing compartment (if present) achieved within the test period (after stabilization). No standard set for the cool-down time but the period will be reported.

Rejection criterion: Failure to stabilize within the [acceptable temperature range\(s\)](#). Halt the test if the appliance does not initially stabilize within the period specified by the [legal manufacturer](#), plus one day.

5.3.4 Test 3: Humidity control

- **Power:** Continuous.
- **Step 1:** When the internal temperature is stabilized at the end of Test 2 (compartment stabilized between +2-8°C, chamber +43°C and relative humidity of 65%), start recording humidity and temperature monitors at a rate of one measurement per minute.
- **Step 2:** Open the lid or door of the appliance and start a 5-minute timer.
- **Step 3:** Load the appliance with the pre-conditioned Dummy Evaporative Load described in Annex 1. Ensure that the water-pack freezing compartment (if present) is empty.
- **Step 4:** At the conclusion of the 5-minute period, close the lid or door of the appliance and let it run for 4 hours.
- **Step 5:** After this initial 4-hour period, continue recording temperature and relative humidity every minute for 24 hours. This will be the test period.

Acceptance criteria:

If the following acceptance criteria are met, the vaccine refrigerator will be recognized as having Humidity Control.

1. Stabilized internal temperatures maintained between +2°C and +8°C in the vaccine storage compartment and below -3°C in the water-pack freezing compartment (if present).
2. Average compartment humidity at or below 55% for the duration of the 24-hour test period.
3. Compartment humidity does not exceed 65% for the duration of the 24-hour test period.

Rejection criteria: Failure to maintain the required average compartment humidity, with no excursion above 65% humidity, for the duration of the test period and within the required temperature range.

NOTE: As of the publishing of this verification protocol version, refrigerators will be required to be tested for humidity control as part of the laboratory verification protocol, but compliance with the humidity control acceptance criteria will not be required until publishing of an updated version of this document. The results of the testing must still be reported. The intended time frame will be to require compliance as of January 2023, pending review of equipment performance tests up to that time and publication of updated specifications and verification protocols.

5.3.5 Test 4: Stable running and continuous power consumption

- **Power:** Continuous.
- **Step 1:** After completing Test 3, remove the dummy evaporative load and load the appliance with simulated, pre-conditioned vaccine as described in Annex 1. Ensure that the water-pack freezing compartment (if present) is empty.

- **Step 2:** Close the lid or door of the appliance and leave it to stabilize the internal temperatures between +2°C and +8°C and reach a state where the compressor or cooling circuit is cycling due to thermostat regulation.
- **Step 3:** After temperature stabilization has been achieved, record temperatures every minute for 24 hours. During this period measure the energy consumption and determine the compressor or cooling circuit duty cycle. Measure the duty cycle by timing from the end of one cycle to the end of a corresponding cycle approximately 24 hours later. Calculate the percentage 'on' time over this period. Measure electricity consumption over the same time scale and report as kWh/day.

Acceptance criteria: Stabilized internal temperatures maintained between +2°C and +8°C in the vaccine storage compartment and below -3°C in the water-pack freezing compartment (if present). No standard set for power consumption but the figure will be reported.

Rejection criterion: Failure to meet one or more of the acceptance criteria.

5.3.6 *Test 5: Stable running and intermittent power consumption*

- **Power:** Intermittent.
- **Step 1:** Continue the Test 4 conditions but with intermittent power of 20 hours of continuous power followed by 4 hours with no power per 24-hour day and the same temperature monitoring regime, but cycle the power supply intermittently until the temperature has re-stabilized and a minimum of three repeating 24-hour temperature profile cycles have been completed⁴.
- **Step 2:** From the start of the next intermittent power-on cycle, measure the energy consumption and determine the compressor or cooling circuit duty cycle. Measure the duty cycle by timing from the start of the power-on cycle to the end of the same cycle (i.e., 20 continuous hours). Calculate the percentage 'on' time over this period. Measure and report electricity consumption over the same time scale and report as kWh/day.

Acceptance criterion: Stabilized internal temperatures maintained between +2°C and +8°C in the vaccine storage compartment. No standard set for power consumption but the figure will be reported.

Rejection criterion: Failure to meet the acceptance criterion.

5.3.7 *Test 6: Water-pack freezing capacity, storage compartment capacity and power consumption*

- **Application:** Combined appliances only.
- **Power:** Intermittent.
- **Step 1:** Continue the Test 4 conditions. Commence with intermittent power cycle of 20 hours of continuous power followed by 4 hours with no power. DO NOT adjust the freezer thermostat.

⁴ With intermittent power, the load temperature may fluctuate over each 24 hour cycle.

- **Step 2:** Stabilize water-packs at +43°C.
- **Step 3:** Load a minimum of 1.6 kg of water-packs and not less than 2.4 kg per 50 litres of gross freezer volume of water-packs into the freezer compartment. Load the packs in accordance with user instructions including any rack or structure provided. Install the freezer thermocouples, centred as uniformly as possible between the loaded water-packs. The minimum distance between a thermocouple and the lid/door, wall or evaporator should be 30mm.
- **Step 4:** Record freezer and refrigerator compartment temperatures every minute for the following 24 hours. Measure electricity consumption and the cooling system duty cycle over the same duration.
- **Step 5:** At the end of the 24-hour test period check that the water-packs are fully frozen (refer to Annex 4 for methodology measurement of ice production). Check that the vaccine load has remained within the +2°C and +8°C range throughout the 24-hour test period. Remove the frozen water-packs.
- **Step 6:** Repeat steps 3 to 5 introducing larger loads of stabilized water-packs up to the point when one or more of the following conditions occurs:
 - the total net weight of fully frozen water-packs has not increased since the previous cycle; or
 - until the freezing compartment is full; or
 - the temperature of the vaccine load breaches the +2°C to +8°C range on one or more sensors.

Establish and record the maximum weight of water-packs that can be fully frozen whilst still meeting the requirements of specification clause 4.2.5 (refer to Annex 4 for the methodology for measurement of ice production). This is the appliance's daily water-pack freezing capacity. Measure electricity consumption over the same time scale and report energy consumption in kWh/day.

- **Step 7:** At the start of the next continuous power phase of a 24-hour cycle load water-packs equal to the minimum daily water-pack freezing capacity determined in Step 6 into the freezer compartment in accordance with user instructions which includes any rack or structure provided for holding water-packs. The process to achieve the maximum freezing capacity must be stated in the user instructions.
- **Step 8:** Record freezer and refrigerator compartment temperatures every minute for the following 24 hours. Measure electricity consumption and the cooling system duty cycle over the same duration. Report energy consumption in kWh/day, percentage on-time over the same time scale and graphically display on/off cycles.
- **Step 9:** At the end of the next continuous power phase remove all water-packs and quickly determine which are fully frozen and which are not fully frozen per instructions in Annex 1 – Fully frozen water-pack determination. Record each water-pack volume, location and condition (i.e. fully frozen or not fully frozen). Replace all packs immediately and add more stabilized water-packs in accordance with user instructions. Note: It must be possible to remove frozen water-packs without any undue force or delay. Defrosting the freezer to enable removal is not acceptable.
- **Step 10:** Repeat Steps 7 to 9 up to the point when either:
 - the total net weight of fully frozen water-packs has not increased

- since the previous cycle; or
- until the freezing compartment is full; or
- the temperature of the vaccine load breaches the +2°C to +8°C range on one or more sensors.

The number and volume of fully frozen [water-packs](#) at the end of Step 10 are to be reported. This is the appliance's [water-pack storage compartment capacity](#).

Acceptance criteria (water-pack freezing capacity): Stabilized internal temperatures maintained between +2°C and +8°C in the [vaccine storage compartment](#). For freezers of less than 50 litres of gross freezer volume a minimum of 1.6 kg of fully frozen [water-packs](#) must remain fully frozen at the end of a 24-hour test phase whilst maintaining the temperature control specified in 4.2.7. For freezers with at least 50 litres of gross freezer volume a minimum of 2.4 kg of fully frozen [water-packs](#) per 50 litres of gross freezer volume must remain fully frozen at the end of a 24-hour test phase whilst maintaining the temperature control specified in 4.2.7. No standard set for power consumption but report the energy consumption in kWh/day, the percentage on-time during the test time and graphically display on/off cycles.

Acceptance criteria (water-pack storage compartment capacity): Stabilized internal temperatures maintained between +2°C and +8°C in the vaccine storage compartment. For freezers of less than 50 litres of gross freezer volume a minimum of 3.4 kg of fully frozen [water-packs](#) must remain fully frozen at the end of Step 10 whilst maintaining the temperature control specified in 4.2.7. For freezers with at least 50 litres of gross freezer volume a minimum of 4.8 kg of fully frozen [water-packs](#) per 50 litres of gross freezer volume must remain fully frozen at the end of Step 10 whilst maintaining the temperature control specified in 4.2.7. No standard set for power consumption but report the energy consumption in kWh/day, the percentage on-time during the test time and graphically display on/off cycles.

Rejection criterion: Failure to meet one or more of the acceptance criteria.

5.3.8 Test 7: Day/night, frozen water-pack storage and power consumption

- **Application:** Day/night and power consumption apply to all appliances. Frozen [water-pack](#) storage instructions apply only to combined appliances.
- **Power:** Intermittent.
- **Step 1:** Incorporating the result from Test 5, allow the appliance to stabilize for a further 24 hours only with the [water-pack](#) freezing compartment filled equivalent to the final [water-pack storage compartment capacity](#) result from Test 6.
- **Step 2:** For further loading (see Step 6), label and stabilize additional water-packs at +43°C.
- **Step 3:** Commencing with the start of the intermittent power phase begin with a 12 hour day phase of a 24 hour solar cycle hold the temperature of the test chamber to M:+27°C, T:+32°C, H:+43°C, for a further 12 hours. Then lower the temperature to M:+10°C, T:+15°C, H:+25°C over a 3 hour period. Hold at M:+10°C, T:+15°C, H:+25°C for a further 9 hours. Next

raise the ambient temperature to M:+27°C, T:+32°C, H:+43°C over a further 3 hour period. Hold at M:+27°C, T:+32°C, H:+43°C for a further 9 hours. Repeat this simulated day-night cycle for five complete 24-hour cycles in total.

- **Step 4:** At the end of the first cycle of 20 hours of power on followed by 4 hours with power off remove a minimum of 1.6 kg of packs and not less than 2.4 kg per 50 litres of gross freezer volume of packs from the freezer compartment. These packs will not be returned to the freezer at this time.
- **Step 5:** Record compartment temperatures every minute for the whole test. Measure electricity consumption and the cooling system duty cycle over the same test duration and report energy consumption in kWh/day, the percentage on-time over each 24-test phase and graphically display on/off cycles.
- **Step 6:** At the end of the 20-hour power on phase load [water-packs](#) which have been stabilized at +43°C. This loading replaces the packs removed in Step 4.
- **Step 7:** At the end of the 4-hour power off phase, record each pack volume, location and condition (i.e. fully frozen or not fully frozen) per instructions in **Annex 1**- Fully frozen [water-pack](#) determination. Except for packs which are to be removed in Step 4, return packs to exact positions without delay.
- **Step 8:** Repeat steps 3 to 7 until five complete day-night cycles have been completed. If possible, packs removed in each repetition of Step 4 must include packs by rotation not previously removed. Record and report the maximum number and volume of fully frozen packs that can remain fully frozen at the end of every night-time phase.
- **Step 9:** Review the data and calculate the MKT for each sensor in the vaccine storage compartment over the five-day period. Record the highest and lowest temperatures reached during the test.

Acceptance criterion: Vaccine storage compartment temperatures must remain within the [acceptable temperature range](#) throughout the test. The MKT of the worst-case sensor must not be outside the range +2°C to +8°C. No standard set for the number of fully frozen and non-fully frozen packs at the end of each power off phase but results to be reported as the quantity and volume of stored frozen water-packs that can remain fully frozen at the end of testing over a five-day period. No standard set for power consumption but report the energy consumption in kWh/day, the percentage on-time during the 5 day test time and graphically display on/off cycles.

Rejection criterion: Failure to meet one or more of the acceptance criteria.

5.3.9 Test 8: Compressor starting

- **Power:** Continuous.
- **Step 1:** Empty the appliance.
- **Step 2:** Switch on the appliance using a starting voltage 20% lower than the nominal voltage of the compressor.
- **Step 3:** Repeat Step 2 ten times from cold with the compressor at +43°C.

- **Step 4:** Repeat Step 2 ten times with the compressor at its normal stable running temperature.
- **Step 5:** Reduce the voltage to -22% of the nominal voltage, repeating steps 2 to 4 for each voltage.
- **Step 6:** If there is a test failure at or before the -22% voltage test, establish the likely cause of the problem and include the diagnosis in the test report.

Acceptance criterion: Ten out of ten starts must be successful in both cold start and hot start tests at a minimum of 22% below the manufacturer's nominal voltage.

Rejection criterion: One or more start failures.

5.3.10 Test 9: Holdover time

- **Power:** Intermittent.
- **Step 1:** For appliances without water-pack freezing, continue the Test 4 conditions. For combined appliances, continue the Test 5 conditions but with the water-pack freezing compartment empty.
- **Step 2:** Provide intermittent power until the refrigerator and freezer temperatures have re-stabilized.
- **Step 3:** At the end of the next power-on cycle, switch off the power supply. If the compressor has already cycled off at this point record the elapsed time since the end of the previous compressor-on cycle (t).
- **Step 4:** Monitor the temperature of the vaccine load at one-minute intervals. At the moment when the warmest point in the load exceeds +8°C record the elapsed time since power supply switch off and add this to the value 't' recorded in Step 3. Record the position of the warmest point.

Acceptance criterion: A minimum of 20 hours at a continuous ambient temperature of +43°C. The report must also place the appliance into the appropriate holdover category, as defined in specification clause 4.2.11.

Rejection criterion: Failure to meet the minimum holdover period for which the appliance is rated.

5.3.11 Test 10: Freeze protection classification

- **Power:** Continuous.
- **Step 1:** At the end of Test 9, immediately switch on continuous power to the appliance and monitor the temperature of the vaccine compartment at one-minute intervals.
- **Step 2:** Maintain continuous power until the appliance cools down and the temperatures stabilize.

Acceptance criteria: To receive a **Grade A** for [freeze protection classification](#), the appliance's cool-down temperatures:

- Must not drop below 0°C for longer than 1 hour.
- Must not reach -0.5°C for any amount of time.

- Following any excursion below 0°C, within 2 hours the appliance must return to the [acceptable temperature range](#) (i.e., consistently between +2°C and +8°C).

Rejection criterion: Failure to maintain [acceptable temperature range](#) during cool-down and stabilization.

5.3.12 Test 11: Door opening

- **Power:** Continuous.
- **Step 1:** Continuing from Test 10, after an additional 1 hour of continuous power, open all compartment lids/doors of the appliance. This must include primary as well as secondary lids/doors, since some appliances have secondary lids/doors. Allow the compartment to stay fully open for 10 minutes.
- **Step 2:** Once 10 minutes have passed, close the lid/door and monitor temperatures of the vaccine compartment for at least 2 hours as the appliance cools down and internal temperatures stabilize.

Acceptance criteria: To receive a Grade A for [freeze protection classification](#), the appliance's cool-down temperatures:

- Must not drop below 0°C for longer than 1 hour.
- Must not reach -0.5°C for any amount of time.
- Following any excursion below 0°C, within 2 hours the appliance must return to the [acceptable temperature range](#) (i.e., consistently between +2°C and +8°C).

Rejection criteria: Failure to maintain [acceptable temperature range](#) during cool-down and stabilization.

5.3.13 Test 12: Minimum rated ambient temperature

- **Power:** Intermittent.
- **Step 1:** Continuing from Test 11, stabilize the test chamber at +10°C or at a lower temperature specified by the manufacturer rounded up or down to the nearest 5°C⁵. At the same time, for combined appliances, stabilize the minimum specified [water-pack freezing capacity](#) load at the current ambient temperature⁶.
- **Step 2:** Load the appliance with simulated, pre-conditioned vaccine as described in Annex 1.
- **Step 3:** Switch the appliance on with intermittent power and stabilize the vaccine load temperature between +2°C and +8°C and the water-pack freezing compartment (if present) below -3°C. At the same time, for combined appliances, stabilize the minimum specified water-pack load at the current ambient temperature.

⁵ For example, if the manufacturer's rated minimum operating temperature for a temperate climate appliance is +3°C, start the test at +5°C. If no minimum temperature is given, start the test at +10°C.

⁶ 'Minimum load' in this context is the gross volume of [water-packs](#) needed to produce the acceptable minimum mass of ice (1.6kg or 2.4kg) at the end of a night-time phase as established in Test 4.

- **Step 4:** Load the stabilized water-packs (combined appliances only) and leave the appliance to run for 24 hours.
- **Step 5:** Run the appliance for a minimum of 72 hours at test chamber ambient of +10°C or at a lower temperature if specified by the manufacturer. Record temperatures every minute. At the end of every 24-hour period, remove the [water-packs](#) from the freezing compartment (if applicable) and check that they are fully frozen to the minimum [water-pack freezing capacity](#) established in Test 5. Return the packs to the freezer immediately.
- **Step 6:** After a minimum of 72 hours of operation determine which of the two conditions apply.
 - Condition 1: The vaccine load has remained within the +2°C to +8°C range and (in combined appliances only) [water-packs](#) are fully frozen as defined in Step 5. Conclude the testing.
 - Condition 2: The vaccine load has not remained within the +2°C to +8°C range and/or (in combined appliances only) [water-packs](#) are not frozen as defined in Step 5. Raise the temperature of the test chamber by 5°C or to a maximum of +10°C and repeat steps 1 to 5. Halt the test cycle if the appliance fails at +10°C.
- **Step 7:** Report and graphically display the test chamber ambient temperatures, appliance temperatures and condition of [water-packs](#) through the entire test starting with Step 1 through the completion of Step 6. If the appliance passes the testing report the [minimum rated ambient temperature](#).

Acceptance criteria: Record the lowest temperature increment at which the vaccine load temperature remains within the +2°C to +8°C range throughout the 24-hour cycle and the minimum [water-pack](#) load (if applicable) is fully frozen by the end of the cycle. This temperature is the [minimum rated ambient temperature](#) for the appliance⁷ and this figure, if not 0°C or any multiple of 5°C, is then rounded up to the nearest 5°C and must be +10°C or lower. The result will be printed in the blue sector of the temperature zone symbol (see **E003/RF03.7 Annex 1**).

Rejection criterion: Failure to pass the test at a simulated temperature of +10°C or lower.

5.4 Test criteria for qualification

A final report must be issued after all testing is complete. The report of the tests must contain the following data and analyses:

- **Summary:** Conclusions and recommendations, including confirmation of the temperature zone(s) for which the appliance is suitable.
- **Test 1:** Comments on samples received, tabulated data on the type-examination test, certifications, and relevant photographs.
- **Test 2:** Results of cool-down test, including hours to initial stabilization, temperature and power graphs.

⁷ Although the test chamber may reach -15°C during the test, the [minimum rated ambient temperature](#) will never be below -10°C.

- **Test 3:** Results of humidity control test including indication of compliance or non-compliance with the bulleted acceptance criteria, calculated average humidity of the defined test period, absolute maximum instantaneous relative humidity during the defined test period, and graphs of the temperature and relative humidity from test start to end.
- **Test 4:** Results of stable running and power consumption test (continuous power), including temperature and power graphs.
- **Test 5:** Results of stable running and consumption test (intermittent power), including temperature and power graphs.
- **Test 6:** If applicable, results of water-pack freezing capacity, storage compartment capacity test, including temperature and power graphs.
- **Test 7:** Results of day/night and freezer storage capacity tests, including MKT analysis, temperature and power graphs.
- **Test 8:** Results of compressor starting test.
- **Test 9:** Results of holdover time test, including temperature and power graphs.
- **Test 10:** Results of the freeze protection classification test, including temperature graphs. Refer to Annex 5 for methodology for freeze protection analysis and grading.
- **Test 11:** Results of the door opening test, including temperature graphs.
- **Test 12:** Results of minimum rated ambient temperature test, including temperature graphs.
- **Excursion analysis:** MKT excursion analysis based on test data in accordance with the [acceptable temperature range](#) definition.
- **Annexes:** Description of the test apparatus. Test chamber temperature records. Copy of reference thermometer calibration certificate(s). Diagrams showing the location and identification codes for temperature sensors, clearly distinguishing between sensors measuring vaccine, water-pack, freezer and evaporator temperatures. Additional supporting documentation requested and received from the [legal manufacturer](#) or [reseller](#) during the course of the type-testing.

6. Quality control checklist

6.1 Quality control standards

All testing and reporting must be carried out in accordance with the requirements of **ISO 17025:2005** or later edition.

6.2 Quality control checklist

An on-site inspection of the manufacturing plant is not required.

6.3 Quality control evaluation

Not required.

7. Prequalification evaluation

An appliance will qualify for inclusion on the register of PQS prequalified ice-lined refrigerator appliance in accordance with WHO procedures provided the final report indicates full conformity with the requirements of specification **E003/RF03.7.**

8. Modified appliances

The [legal manufacturer](#) or [reseller](#) must notify WHO [in writing](#) of any changes which affect the performance of the appliance. WHO will carry out a desk evaluation of the reported change(s). If any change is deemed adversely to affect the performance of the appliance, WHO may request full or partial re-verification based on the test procedures described in this document.

Annex 1 – General test conditions

The following conditions are applicable to all refrigerator and freezer tests.

Test conditions:

- Carry out tests in a test chamber in which temperatures can be controlled to $\pm 1^{\circ}\text{C}$ and humidity to $\pm 10\%$ unless otherwise stated below. Measure test chamber temperatures in accordance with IEC 62552, clause 8.2.
- Maximum test chamber temperatures of $H: +43^{\circ}\text{C}$ is required for the tests.
- Minimum test chamber temperatures down to -15°C may be required for the [minimum ambient temperature rating](#) test. The actual minimum required for a specific appliance should be discussed with the appliance manufacturer before the test commences.
- Temperatures within the appliance must be continuously monitored to an accuracy of $\pm 0.5^{\circ}\text{C}$ without the presence of the sensors influencing the test in any way. Thermocouples that are sealed within the appliance are most commonly used. Up to 16 simultaneous temperature measurements may be required for a single appliance. The suggested temperature sensor locations are shown in Annex 2. See Annex 3 for temperature sensor specifications.
- Position the test appliance in the test chamber with its back face 50 mm clear of one of the chamber walls. Ensure that it is accurately levelled.

Stabilization times:

Initial stabilization is accomplished when the appliance demonstrates all of the following:

- The thermal storage has been cooled for a time period no less than the cool down time period stated in the instructions provided by the manufacturer. (e.g. if instructions state cool down time is 3 days then at least a 3-day cool down test is required); and
- The internal temperatures in the vaccine storage compartment are within the [acceptable temperature range](#); and
- The cooling system has exhibited consistent on/off operation for the final two days of this test (e.g. the same number of on/off cycles per day for the final two days).

Before measuring the performance of a refrigerator or freezer under normal running conditions, internal temperature conditions in the [vaccine storage compartment](#) must be stable. This is normally assumed to have occurred when either:

- The thermostat has been cycling for 24 hours, or
- The temperature at each of corresponding points during successive operating cycles varies by less than $\pm 1^{\circ}\text{C}$ and there is no marked trend away from the mean temperature at that point over 24 hours.

Vaccine net storage capacity measurement:

- Measure [vaccine storage capacity](#) using cardboard boxes, plastic foam or wooden blocks, 100 x 100 x 100 mm, 100 x 100 x 50 mm, and 50 x 50 x 50 mm.
- Fill the appliance up to the maximum loading line recommended by the manufacturer.

- Where baskets and shelves are supplied, these should be used to hold the dummy load. Do not place any boxes outside the zone designated by the manufacturer for vaccine storage.
- Do not place the dummy load in the fast freeze compartments of vaccine freezers.

Recording temperatures:

- Test appliances, either loaded or empty, as described above in the verification protocol.
- Take temperature and humidity readings once per minute.

Sensor placement:

- Place sensors in contact with the surfaces of the [vaccine storage compartment](#) and at the centre of the vaccine load as well as at other positions which are likely to experience extremes of temperature. Such positions might be near door seals or where air circulation is restricted by the appliance design. See the Annex 2 sensor position diagrams and notes.
- For non-Grade A appliances and where vaccine storage baskets are required to avoid [freezing temperatures](#), fix sensors within the volume(s) defined by the internal faces of the basket(s).
- Fix the sensors in position so that they cannot be displaced during the course of the tests. Sensors may be fixed in position using thin rigid wire, tape or similar materials which do not affect the thermal performance of the appliance.
- After initial setup, do not alter the position of sensors during subsequent tests.
- Monitor all sensors so that an overall picture of the temperature distribution can be obtained.

Humidity sensor:

- Follow the existing guidelines outlined for temperature sensor placement in Annex 2.
- Place the humidity sensor at the same location as temperature sensor #19 (refer to Annex 2). Humidity sensor location must be < 10 cm away from this temperature sensor.
- The humidity sensor must be accurate to $\pm 3\%$ in the range of 25% to 75%.

Dummy vaccine load:

Make up a dummy vaccine load⁸ using partially filled [water-packs](#).

- Measure the chosen water-packs to establish their nominal unit volume in litres (length x width x thickness in cm/1000).
- Select the number of empty [water-packs](#) required to build a dummy load whose nominal volume is equal to the measured [vaccine net storage capacity](#) in litres divided by five, $\pm 5\%$.

⁸ The dummy load described below is intended to approximate the minimum vaccine load in a well-managed refrigerator holding a 25% safety stock.

- Partially fill the [water-packs](#) with equal volumes of water so that the mass of the load is equal to the nominal load volume x 0.4 kg (0.4 kg per litre). Pre-condition the dummy load at +8°C and place in the appliance as follows so that it does not interfere with the sensor positions already established:

Front-opening appliances:

- Stack the partially filled [water-packs](#) evenly on the shelves designated for vaccine storage.

Top-opening refrigerators:

- Stack the partially filled [water-packs](#) evenly on the bottom of baskets supplied for vaccine storage.
- If baskets are not required to keep vaccine away from the base and walls of the appliance, stack the partially filled [water-packs](#) evenly on the base of the appliance.

Top-opening freezers:

- Stack the partially filled [water-packs](#) evenly on the base of the appliance.

Dummy evaporative load:

A dummy evaporative load will be used in place of the dummy vaccine load for the humidity control test. General test conditions of the dummy vaccine load will apply to the dummy evaporative load.

Prepare a dummy evaporative load using open-top glass containers.

- The internal height of the container shall be at least 2.0 cm.
- Measure the surface area of the container opening in cm² (length x width for rectangular dishes, diameter x diameter x 0.785 for circular dishes). If the container has drafted walls, measure the length, width, and/or diameter at a height of 0.5 cm below the top rim.
- Select the number of containers required to build a dummy evaporative load whose surface area in cm² is equal to the measured vaccine net storage capacity in litres multiplied by six, $\pm 10\%$.
- Estimate the volume required to fill all the dummy evaporative load containers to within 0.5 cm of their tops. Fill a separate water storage container with at least that much water.
-

Pre-condition the dummy evaporative load and filled water storage containers at +8°C. Fill the dummy evaporative load containers with conditioned water to within 0.5 cm from the top of each container and place in the appliance as follows so that they do not interfere with the sensor positions already established:

Front-opening appliances:

- Place the filled containers spaced approximately evenly from each other and the walls and door on the shelves designated for vaccine storage.

Top-opening refrigerators:

- Place the filled containers spaced approximately evenly from each other and the walls and door on the bottom of baskets supplied for vaccine storage.
- If baskets are not required to keep vaccine away from the base and walls of the appliance, place the filled containers evenly on the base of the appliance.

Water-packs:

Tests which require water-packs must use 0.3, 0.4 or 0.6 litre water-packs conforming to PQS specification **E005/IP01**.

Dual compressor or multiple cooling circuit appliances:

Both compressors should be switched on during all tests.

Multi-fuel and multi-function appliances:

- Multi-fuel appliance (typically absorption refrigerators or freezers) will be lengthy and costly to test, so a decision on which options should be tested will be made by WHO on a case by case basis.
- In the case of appliances which can be run either as a freezer or as a refrigerator, the first set of tests should test the refrigerator function and the second set should test the freezer function.



Annex 2 – Temperature sensor positions

Approximate sensor positions are indicated by the Annex 2 figures. Except for ambient sensors placed centrally in a compartment the surface sensors are positioned in direct contact with the [vaccine storage compartment](#). If baskets are used to define the [vaccine storage compartment](#), all sensors are to be located inside the basket(s) and the surface sensors are to be in contact with the basket material and as shown in the Annex 2 figures.

The surface sensors that are to be placed in direct contact with the walls of the vaccine storage compartment are not to be inserted into brass or tin-covered copper mass, as required in the previous version of this protocol. These surface sensors must be directly in contact with the walls of the vaccine storage compartment. However, the ambient sensors that are placed in more central locations in the vaccine storage compartment are to remain in a brass- or tin-covered copper mass.

UPRIGHT COMPARTMENT




- 17 Surface sensors
- 2 Ambient sensors



All sensors are to be positioned according to this layout and in direct contact with compartment surfaces.

UPRIGHT COMPARTMENT – WITH FREEZER



- 17 Surface sensors
- 5 Ambient sensors



All sensors are to be positioned according to this layout and in direct contact with compartment surfaces.

CHEST COMPARTMENT – NO STEP



- 17 Surface sensors
2 Ambient sensors



All sensors are to be positioned according to this layout and in direct contact with compartment surfaces.

CHEST COMPARTMENT – WITH STEP



- 17 Surface sensors
2 Ambient sensors



All sensors are to be positioned according to this layout and in direct contact with compartment surfaces.



CHEST COMPARTMENT – WITH FREEZER

- 17 Surface sensors
5 Ambient sensors



CYLINDRICAL CHEST COMPARTMENT

- 13 Wall sensors
2 Ambient sensors



Annex 3 – Temperature sensor specification

Surface sensors in contact with the vaccine compartment surfaces must comply with **IEC 62552**, clause 8.7.1 with probe accurate to $\pm 0.5^{\circ}\text{C}$ but are not to be inserted into brass or tin-covered copper mass of $25\text{ g} \pm 5\%$. Ambient sensors not in contact with the vaccine storage compartment are to comply with **IEC 62552**, clause 8.7.1 with sensor, accurate to $\pm 0.5^{\circ}\text{C}$, inserted into brass or tin-covered copper mass of $25\text{ g} \pm 5\%$ and of minimum external area (diameter = height = about 15.2 mm).

Annex 4 – Methodology for measurement of ice production

The following tests are used to determine whether a [water-pack](#) is fully frozen, partially frozen, or unfrozen. While the assessment is not 100% accurate, misclassifications are usually conservative in nature: [water-packs](#) that are fully frozen are sometimes classified as partially frozen rather than partially frozen [water-packs](#) being classified as fully frozen. A fully frozen [water-pack](#) contains only ice. A partially frozen [water-pack](#) contains both ice and water. An unfrozen [water-pack](#) contains only water

Perform the all of the following tests on the [water-pack](#):

- Shake test - Shake the [water-pack](#) while holding the [water-pack](#) near the assessor's ear. If the sound of water sloshing in the [water-pack](#) is heard, then the [water-pack](#) fails the shake test.
- Tilt test – Tilt the [water-pack](#) back and forth while looking for the movement of air or water in the [water-pack](#). If the movement of air or water is observed, then the [water-pack](#) fails the tilt test.
- Bulge test – Water expands when it freezes. Examine the [water-pack](#) for localized bulging near the centreline of the [water-pack](#) when viewing the [water-pack](#) from the side. If localized bulging is not present, then the [water-pack](#) fails the bulge test.
- Classify the [water-pack](#) as follows:
 - If the [water-pack](#) passes all three tests, then the [water-pack](#) is fully frozen.
 - If the [water-pack](#) fails one or more tests, then the [water-pack](#) is partially frozen or unfrozen and fails the test.

Annex 5 – Methodology for freeze protection analysis and grading

- All data collected and interventions implemented, with the exception of data from Test 2 cool-down, must be evaluated to assign a freeze protection grade according to the definition of [freezing temperatures](#) and the below intervention chart:

User-Intervention	Evaluation Criteria	Result
Basket storage	Any need to utilize baskets to protect vaccines from freezing.	add 1 user-intervention
Compartment covers	Any need to utilize vaccine compartment covers to protect vaccines from freezing.	add 1 user-intervention
Knob adjustment	Any adjustment of temperature knob or fuel regulator required to protect vaccines from freezing.	add 1 user-intervention
Wick adjustment	Any required adjustment of flame wick to operate appliance and/or protect vaccines from freezing.	add 1 user-intervention

NOTE: This list of interventions is representative and does not include all possible user-interventions.

- Freeze protection grading criterion: The refrigerator's grade must be evaluated based on the number of user-intervention required to maintain safe storage within the 2-8°C compartment temperature range.
 - [Grade A, user-independent freeze protection \(UIFP\)](#): zero (0) interventions required.
 - [Grade B, user-dependent freeze protection \(UDFP\)](#): one (1) user-intervention required.
 - [Grade C, user-dependent freeze protection \(UDFP\)](#): greater than one (>1) user-interventions required.
- If at any point during testing, the appliance fails to meet the criteria for "A" grade freeze protection, the testing must be stopped, a manufacturer prescribed intervention implemented and the testing restarted from Test 2. These interventions must be implemented one at a time so as to differentiate between single-intervention "B" grades and multi-intervention "C" grades.

Revision history (revisions since February 8, 2017):			
Date	Change summary	Reason for change	Approved
25.09.2018	Clause 3 (Terms and definitions) PCM definition added.	Reflect change to allowance of water-based and PCM-based buffers	I. Gobina
25.09.2018	Bullet on PCM conformity with relevant product specification and compliance with PCM materials specification added to Clause 5.3.1 (Type examination)	Reflects change to allowance of PCM-based buffer materials as per product specification.	I. Gobina
15.09.2020	Terms & definition updated to include humidity-control	Reflect requirements included in the 2020 Humidity Control TPP	I. Gobina
15.09.2020	Clause 5.3.4 Test 3 added, clause 5.3.5 Test 4 edited, clause 5.4 Test 3 added, Annex 1 & 2 added to all to include / reflect humidity control tests.	Reflect requirements included in the 2020 Humidity Control TPP	I. Gobina
02.12.2024	Added EMS requirement to 5.3.2 Type examination.	EMS is now required for vaccine appliances	I. Gobina